



STANDARD  
CONTROLLER  
LOCATION—

AMBIENT INTAKE FILTER-

-AMBIENT EXHAUST:

OPTIONAL  
CONTROLLER  
LOCATION—

ENCLOSURE  
INTAKE

ENCLOSURE  
EXHAUST


11.310  
[287.27]

— AMBIENT EXHAUST



1 of 2

E	ADDED VOLTAGE AND FREQUENCY TOLERANCE	NAT	9/20/2022			
D	ADDED Aex AND Ex CERTIFICATION INFORMATION	NAT	4/27/2021			21-0186
C	ADDED CFM, dBA, 240V and 440V 50/60HZ, AND CLEARANCE INFO	RCC	4/26/2018	JGG	4/26/2018	1347
B	ADDED METRIC VALUES	ART	1/10/2018	JGG	1/10/2018	1336
REV	REVISION	CHG	DATE	APP	DATE	CN #



**\*IMPORTANT\***  
**GASKET MUST BE APPLIED AS SHOWN FOR PROPER**  
**OPERATION AND TO MAINTAIN ENCLOSURE INTEGRITY**

EVAP. OUTLET ≈ 510 CFM  
COND. OUTLET ≈ 800 CFM  
SOUND LEVEL @5FT FROM UNIT @ A HT. OF 3FT = 68 dBA  
SOUND LEVEL @2FT FROM UNIT @ A HT. OF 5FT = 70 dBA  
CONDENSER INLET MIN. CLEARANCE 3.00"

ITEM NUMBER N/A		USED ON IQ12000EVZ2		UNLESS OTHERWISE SPECIFIED TOLERANCES  X ±.060 .XX ±.030 .XXX ±.015  FRACTIONAL ±1/4 ANGULAR ±1/2°  SURFACE FINISH 63  DO NOT SCALE DRAWING DIMENSIONS ARE INCHES	<div>ICEqube</div> <div>ICE QUBE, INC.</div> <div>THIS IS A PROPRIETARY DOCUMENT. DO NOT REPRODUCE OR DISCLOSE WITHOUT THE EXPRESS WRITTEN PERMISSION OF ICE QUBE, INC.</div>
MATERIAL N/A					
EST WT: lbs				DESCRIPTION IQ12000EVZ2 ZONE 2 ATEX IECEx SPEC DRAWING	
DRAWN BY ART		DATE 1/19/2017	SCALE 1:5	DRAWING NUMBER IQ351313	
				REV E	