

Certificate of Compliance

Certificate Number 2011-01-19 –E335729
Report Reference E335729, 2010 December 14
Issue Date 2011-01-19

Page 1 of 1



Issued to: Ice Qube Inc

141 Wilson Ave
Greensburg, PA 15601

*This is to certify that
representative samples of*

Room Air Conditioners For Use In Hazardous Locations

USL, CNL – Models IQ, followed by 2000VXS, 2000TXS, 2000TXS-M1, 2200VB, 2200VS, 2400VXS, 2500TXS, 2500V, 3000T, 3000VS, 3500V, 4000T, 4000V, 4000V16HA, 4000VS, 4500V, 5000T, 5000V, 5000V16, 5000V16HA, 5500VS, 6000V, 6000T, 6000V16, 6000V16HA, 8000VHA, 8000V16, 10000V, 12000V, 14000V, 17000V, 20000V for use in Class I, Division 2, Groups B, C and D Hazardous Locations.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 484 Room Air Conditioners.
ANSI/ISA 12.12.01, 2007, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.
UL 1203, 4th Ed., Rev. 2009-10-28, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.
CAN/CSA C22.2 No. 30-M1986, Rev. 1988-11, Explosion-Proof Enclosures for Use in Class I Hazardous Locations.
CAN/CSA C22.2 No. 213-M1987, 1st Ed., Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.

Additional Information:

See UL On-line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: Russell Filip

Senior Staff Engineer
Underwriters Laboratories Inc.

Reviewed by: John A. Zaplatosch

Engineering Manager
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL